

An engineered natural turf soccer field should have a minimum of one-and-one-half percent (1.5%) slope for fields which are surface drained. For natural turf fields with a sub-surface drain system the slope should be no less than one (1.0%) percent. For synthetic turf fields with a sub-surface drain system the slope should be no less than one half of one (0.5%) percent. Slope is measured from center to side. For consulting services, contact SportsPLAN Studio, 816-842-5200.